

EU Type Examination Certificate Number: **0120/SGS0670**

**F&F Filipowski sp.k.**

ul. Konstanyńska 79/81, 95-200 Pabianice, Poland

Instrument Identification:  
**WZE-3-1, WZE-3-RST, LE-03-FPV-RST, LE-03-FPV-RST-M1, LE-03-FPV-RST-M2**

**Polyphase, Active Import/Export (kWh), Electricity Meter**

Instrument Traceable Number  
**0120/SGS0670**

has been assessed and certified as meeting the requirements of

**EU Directive 2014/32/EU**  
**on Measuring Instruments Annex II, Module B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU


This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 20<sup>th</sup> April 2026  
Issue 1

Certification is based on report number(s):


Certification is based on report number(s): SHES151000648101 dated 19<sup>th</sup> April 2016  
EMA288418/1 dated 1<sup>st</sup> April 2021, EMA288737/3 dated 1<sup>st</sup> April 2021, EMA288418.1p2w dated 4<sup>th</sup> July 2022, EMA314862/1 dated 18<sup>th</sup> April 2023  
EMA319594/1

Authorised Signature



Tuomas Hänninen

SGS Fimko OY, Notified Body 0598  
Takomotie 8, FI-00380 Helsinki, Finland  
t +358 9 6963 61 [www.sgs.fi](http://www.sgs.fi)





EU-Type Examination Certificate Number:

**0120/SGS0670**

Issue Number: 1

Dated: 14<sup>th</sup> November 2023**1. Technical Data**

<b>Manufacturer</b>	F&F Filipowski sp.k.
<b>Meter Type</b>	WZE-3-1, WZE-3-RST, LE-03-FPV-RST, LE-03-FPV-RST-M1, LE-03-FPV-RST-M2
<b>Voltage Rating (<math>U_n</math>)</b>	230V & 3 x 230/400V
<b>Current Rating (<math>I_{min}</math> – <math>I_{ref}</math> (<math>I_{max}</math>))</b>	0,5-10(100)A & 0.5-10(80)A
<b>Frequency (<math>F_n</math>)</b>	50Hz
<b>Active Accuracy Class (<math>kWh</math>)</b>	B ( $kWh$ )
<b>Type of circuit</b>	3p4w, 1p2w
<b>Temperature Range</b>	-40°C to +70°C
<b>Software/ Firmware Version No's</b>	WZE-3-1: V1.1                      CRC: 0282 WZE-3-RST: V1.1                  CRC: 0283 LE-03-FPV-RST: V1.1              CRC: 0284
<b>CRC Checksum No's</b>	LE-03-FPV-RST-M1: V1.3        CRC: 0388 LE-03-FPV-RST-M2: V1.3        CRC: 0388
<b>Identification Location</b>	Laser printed on meter case & LCD
<b>Bill Of Materials No's</b>	WZE-3-1: V1.2 WZE-3-RST: V1.2, LE-03-FPV-RST: V1.2 LE-03-FPV-RST-M1: DH-JS-200010-1.2 LE-03-FPV-RST-M2: DH-JS-200010-1.2
<b>IP Rating</b>	IP51
<b>Insulation Protective Class</b>	Class II
<b>LED Pulse Constant</b>	1000 imp/kWh or 100imp/kWh
<b>Impulse Voltage Rating</b>	6kV
<b>AC Voltage Rating</b>	4kV
<b>Main Cover Sealing Type</b>	Wire & Crimp on terminal cover Meter case sealed with screws
<b>Integrity of meter</b>	Inaccessible without breaking seals
<b>Intended Location of the Meter</b>	Indoor
<b>Type of Register</b>	LCD
<b>Terminal Arrangement(s)</b>	DIN
<b>Location of Manufacturers Address</b>	Associated documents

**SGS**


EU-Type Examination Certificate Number:

**0120/SGS0670**


Issue Number: 1

Dated: 14<sup>th</sup> November 2023

**2. Photograph of Meter and Sealing Plan**



Terminal cover sealing points



Meter case sealing point



# SGS

EU-Type Examination Certificate Number:

**0120/SGS0670**

Issue Number: 1

Dated: 14<sup>th</sup> November 2023





EU-Type Examination Certificate Number:

**0120/SGS0670**

Issue Number: 1

Dated: 14<sup>th</sup> November 2023

#### 4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$

where

- $\delta e(T, I, \cos\phi)$  = Additional error due to variation of the temperature at the same load
- $\delta e(U, I, \cos\phi)$  = Additional error due to variation of the voltage at the same load
- $\delta e(f, I, \cos\phi)$  = Additional error due to variation of the frequency at the same load

#### 1P2W Configuration

		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
I <sub>min</sub>	1.0	0.10	0.11	0.11	0.07	0.08	0.12	0.17	0.21
I <sub>tr</sub>	1.0	0.07	0.10	0.10	0.06	0.05	0.09	0.15	0.19
10I <sub>tr</sub>	1.0	0.05	0.08	0.08	0.05	0.06	0.09	0.15	0.19
I <sub>max</sub>	1.0	0.18	0.14	0.08	0.03	0.09	0.12	0.15	0.16
I <sub>tr</sub>	0.5ind	0.12	0.13	0.12	0.07	0.07	0.11	0.15	0.19
10I <sub>tr</sub>	0.5ind	0.05	0.08	0.08	0.05	0.07	0.10	0.15	0.18
I <sub>max</sub>	0.5ind	0.11	0.07	0.02	0.07	0.17	0.20	0.22	0.22
I <sub>tr</sub>	0.8cap	0.12	0.14	0.14	0.09	0.03	0.07	0.12	0.16
10I <sub>tr</sub>	0.8cap	0.07	0.10	0.10	0.06	0.05	0.08	0.14	0.17
I <sub>max</sub>	0.8cap	0.19	0.15	0.09	0.04	0.07	0.11	0.14	0.14



EU-Type Examination Certificate Number:

**0120/SGS0670**

Issue Number: 1

Dated: 14<sup>th</sup> November 2023

**3P4W Configuration**

		Influence Factors for Temperature. Frequency & Voltage							
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
I <sub>min</sub>	1.0	0.08	0.32	0.24	0.15	0.12	0.15	0.26	0.70
I <sub>tr</sub>	1.0	0.13	0.34	0.24	0.15	0.10	0.15	0.30	0.61
10I <sub>tr</sub>	1.0	0.26	0.37	0.28	0.17	0.10	0.15	0.28	0.51
I <sub>max</sub>	1.0	0.12	0.30	0.24	0.19	0.15	0.17	0.24	0.44
I <sub>tr</sub>	0.5ind	0.26	0.51	0.45	0.37	0.30	0.30	0.36	0.59
10I <sub>tr</sub>	0.5ind	0.34	0.40	0.32	0.25	0.18	0.22	0.32	0.43
I <sub>max</sub>	0.5ind	0.45	0.66	0.62	0.58	0.52	0.51	0.50	0.40
I <sub>tr</sub>	0.8cap	0.18	0.44	0.34	0.26	0.16	0.17	0.24	0.62
10I <sub>tr</sub>	0.8cap	0.19	0.37	0.25	0.15	0.09	0.15	0.27	0.56
I <sub>max</sub>	0.8cap	0.27	0.48	0.42	0.38	0.33	0.31	0.32	0.44
<b>L1</b>									
I <sub>tr</sub>	1.0	0.19	0.37	0.33	0.29	0.26	0.28	0.38	0.93
10I <sub>tr</sub>	1.0	0.08	0.30	0.21	0.15	0.10	0.17	0.29	1.09
I <sub>max</sub>	1.0	0.29	0.23	0.18	0.17	0.11	0.14	0.23	1.09
I <sub>tr</sub>	0.5ind	0.15	0.44	0.38	0.35	0.34	0.38	0.44	1.16
10I <sub>tr</sub>	0.5ind	0.19	0.31	0.24	0.22	0.19	0.26	0.38	1.25
I <sub>max</sub>	0.5ind	0.31	0.29	0.26	0.25	0.22	0.24	0.34	1.08
<b>L2</b>									
I <sub>tr</sub>	1.0	0.21	0.61	0.61	0.61	0.61	0.61	0.61	0.68
10I <sub>tr</sub>	1.0	0.11	0.19	0.19	0.19	0.19	0.19	0.20	0.49
I <sub>max</sub>	1.0	0.30	0.16	0.14	0.12	0.12	0.12	0.12	0.50
I <sub>tr</sub>	0.5ind	0.53	0.76	0.77	0.77	0.76	0.77	0.77	1.00
10I <sub>tr</sub>	0.5ind	0.48	0.31	0.30	0.30	0.30	0.31	0.32	0.97
I <sub>max</sub>	0.5ind	0.66	0.30	0.28	0.27	0.27	0.27	0.27	0.85
<b>L3</b>									
I <sub>tr</sub>	1.0	0.46	0.80	0.52	0.38	0.27	0.37	0.54	0.17
10I <sub>tr</sub>	1.0	0.70	0.86	0.64	0.50	0.42	0.48	0.63	0.14
I <sub>max</sub>	1.0	0.71	1.09	0.97	0.90	0.87	0.89	0.95	0.68
I <sub>tr</sub>	0.5ind	1.40	1.04	0.92	0.82	0.79	0.82	0.92	0.93
10I <sub>tr</sub>	0.5ind	1.58	1.03	0.88	0.78	0.74	0.78	0.88	1.03
I <sub>max</sub>	0.5ind	1.24	1.02	0.92	0.92	0.83	0.87	0.94	1.08



EU-Type Examination Certificate Number:

**0120/SGS0670**

Issue Number: 1

Dated: 14<sup>th</sup> November 2023

## 5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
WZE-3-1	3x230/400V, 0.5-10(100)A or 0.5-10(80)A 1000imp/kWh or 100imp/kWh Shows only total active energy, without resettable kWh
WZE-3-RST	3x230/400V, 0.5-10(100)A or 0.5-10(80)A 1000imp/kWh or 100imp/kWh Shows total active energy, resettable kWh, total active power
LE-03-FPV-RST-M1	230V or 3x230/400V, 0.5-10(100)A or 0.5-10(80)A 1000imp/kWh or 100imp/kWh Shows total active energy, total active power, import and export energy, resettable import and export energy. RS485 communication.
LE-03-FPV-RST-M2	230V or 3x230/400V, 0.5-10(100)A or 0.5-10(80)A 1000imp/kWh or 100imp/kWh Shows total active energy, total active power, import and export energy, resettable import and export energy, voltage, current, power factor, frequency and demand values. RS485 communication.
LE-03-FPV-RST	3x230/400V, 0.5-10(100)A or 0.5-10(80)A 1000imp/kWh or 100imp/kWh Shows total active energy, total active power, import and export energy, resettable import and export energy

Modifications to the meter(s) described according to approval No.**0120/SGS0670** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).





EU-Type Examination Certificate Number:

**0120/SGS0670**

Issue Number: 1

Dated: 14<sup>th</sup> November 2023

**6. Document Revision History**

Issue	Date	Comments
1	14/11/2023	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested *and such sample(s) are retained for 28 days only.*

**END OF CERTIFICATE**