



Český metrologický institut  
Okružní 31, 638 00 Brno



Notified Body  
No. 1383

tel. +420 545 555 111, fax +420 545 222 728, www.cmi.cz

## EC-TYPE EXAMINATION CERTIFICATE

Number: TCM 221/12 - 4971

**In accordance:** with Directive 2004/22/EC of the European Parliament and of the Council as amended implemented in Czech Republic by Government Order No. 464/2005 Coll. as amended that lays down technical requirements on measuring instruments.

**Manufacturer:** F&F Filipowski Sp.J.  
Ul. Konstancyńska 79/81  
95-200 Pabianice  
Poland

**For:** active electrical energy meter - single-phase  
type: LE-01 MID  
Accuracy class: A or B  
mechanical environment class: M1  
electromagnetic environment class: E2  
temperature range: -25 °C...+55 °C

**Valid until:** 26 August 2022

**Document No:** 0511-CS-A032-12

**Description:** Essential characteristics, approved conditions and special conditions, if any, are described in this certificate.

**Date of issue:** 27 August 2012

Certificate approved by:



  
RNDr. Pavel Klenovský

This certificate was issued according to module B - type examination according to annex B to Directive 2004/22/EC of the European Parliament and of the Council or point 3 of annex 2 to Government Order No. 464/2005 Coll., respectively.